



CYLINDERS SECURED BY NESTING SHALL HAVE THREE POINTS OF CONTACT



RIGHT



NOT ALL HAVE THREE POINTS OF CONTACT

WRONG

ADDITIONAL RESTRAINTS ARE REQUIRED EXCEPT AT GAS SUPPLIERS' FACILITIES AND DISTRIBUTORS' WAREHOUSES